



King County Fire Marshal's Office
Department of Development and Environmental Services
900 Oaksdale Avenue Southwest Renton, WA 98055-1219 (206) 296-6675

Permit No. F96-0953

BOEING BLDG 3-368
C/O RICK FORD
PO BOX 3707 MS 19-35
SEATTLE, WA 98124-2207

RECEIVED
KING COUNTY
AUG 21 2002
INTERNATIONAL
AIRPORT

Date Expires: 05/31/2003

Business Name: BLDG 3-368
Site Address: 7300 EAST MARGINAL WAY S KC
Location:
Fire District: KCA

THIS PERMIT IS GRANTED FOR:

Cond: CON1097435
INSIDE FLAMMABLE LIQUIDS STORAGE: - (CLASS I LIQUIDS); FLAMMABLE LIQUIDS
TO BE STORED IN
APPROVED CABINET - LESS THAN 60 GALS. *
Cond: CON1097436
OUTSIDE A/G COMBUSTIBLE LIQUIDS STORAGE: - 10,000 GALS. JET A FUEL (CLASS II
OR III-A
LIQUIDS)

NOTICE

1. This permit does not take the place of any License required by law and is NOT TRANSFERABLE. Any change in use, occupancy, or ownership of the premises shall require a new permit.
2. THIS PERMIT AND ANY ATTACHED CONDITIONS MUST BE POSTED IN A CONSPICUOUS PLACE ON THE PREMISES.
3. This permit is subject to the satisfactory completion of all corrections identified in the original or renewal inspection and all conditions that are attached.
4. This permit EXPIRES (05/31/2003)
5. Call 296-6675 for inspection requests and information regarding this permit.